

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2000/108/71

Dated: 30.09.2026

It is certified that an inspection team headed by Randall (Assistant Engineer)

(Name of Officers with designation) from UP Jal Nigam (Rural) SRE PHED

inspected the ST. A. M. CONVENT PUB SCHOOL JANDHERAS

(Name & Address of the school) on 29/9/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 6/2026.1 Sep/23 dated 29/9/2026

of District Level Water Analysis Lab (PHED SRE Lab) certified that

the ST. A. M. CONVENT PUB SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 YEAR

Signature with Seal:

Name

Designation

Name & Address of the Office / Department



सहायक अभियन्ता

खण्ड कार्यालय

Randall

जल निगम (ग्रामीण)

Assistant Engineer

(Rural) SRE) 247001.

UP Jal Nigam

To
ST. A. M. CONVENT PUBLIC
SCHOOL JANDHER & AMASPUR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL WATER ANALYSIS LABORATORY,

UP JAL NIGAM (Rural)

Address-Office of Executive Engineer , Construction Unit U.P. Jal Nigam
Near Gandhi Park District - Saharanpur -247001

TEST REPORT (WATER)

Analysis Report		
No.	C/2026/Sep/33	
Client Name	Kavita Verma (Principal-St. A.G.M. Convant Public School)	Date - 29.09.2026
Name And Address	St. A.G.M. Convant Public School, Jandhera Samaspur, Dehli Road, Saharnpur.	Page No. 01
Ref No.& Date.	By Application.....Date:- 28.09.2026	

Basic details of Sample

Location	Saharanpur	Block	NA
Pin	NA	Village/Mohalla/Town/City	Jandhera Samaspur
Source	R.O	Location/Site Name	St. A.G.M. Convant Public School
Q. Sample (ml)	1000 ml	Sample No.	DL/26/09/43
Q. Date	28.09.2026	Date of Sample Collection	28.09.2026
Depositor	Pravindra Kumar	Sample Collector	Deepak Sharma
Date	29.09.2026	Sampling Method	NA
		Analysis Completion Date	29.09.2026

Temperature = 25±3°C

Technical Data of Analysis.

Humidity = 50±15%

Analysed Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
2	3	4	5	6	7
pH (Temp. 25°C)	-	7.39	6.5-8.5	No Relaxation	IS 3025 (Part 11) : 2022
Residue	NTU	3.5	1.00	5.00	IS 3025 (Part 10) : 2023
DO (Temp. 20°C±2°C)	mg/L	320	500	2000	IS 3025 (Part 16) : 2023
Chloride (as Cl)	mg/L	18.99	250	1000	IS 3025 (Part 32) : 2025
Total Alkalinity (as CaCO ₃)	mg/L	278	200	600	IS 3025 (Part 23) : 2023
Total Hardness (as CaCO ₃)	mg/L	308	200	600	IS 3025 (Part 21) : 2023
Fluoride (as F)	mg/L	0.196	1.00	1.50	APHA 24 th Edition-4500-F Method C(Electrode Method) : 2023
Calcium (as Ca)	mg/L	64	75	200	IS 3025 (Part 40) : 2024
Magnesium (as Mg)	mg/L	35.96	30	100	APHA 24 th Edition-3500-Mg Method B(By Calculation) : 2023
Iron (as Fe)	(mg/L)	0.22	0.1	1	APHA 24 th Edition-3500-Fe Method B(Phenanthroline) : 2023
Nitrate (as NO ₃)	(mg/L)	21.3	45	No Relaxation	APHA 24 th Edition-4500-NO ₃ Method D(UV Screening Method) : 2023
Sulphate (as SO ₄)	(mg/L)	29.4	200	400	APHA 24 th Edition-4500-SO ₄ Method E(Turbidimetric Method) : 2023

*****End of the Report*****

This Certificate refers only to the particular sample(s) submitted for testing.

This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from head of Laboratory.

The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.

Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

Parameter above permissible limit are written in bold.

Sample is not collected by laboratory.

(Amit Kumar)
(Reviewed By)

(Amit Kumar)
(Prepared By)

District Level Water Analysis Laboratory
Quality Manager
Deepak Sharma
(Authorized Signatory)